

36

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

dda

1. Location of well: County Jackson Fraction NE SE SE Section number 26 Township number T 7 S Range number R 13 E W

2. Distance and direction from nearest town or city: 10 W 4 S 10. Owner of well: Jake Cell
Street address of well location if in city: Holtan R.R. or street: R.R.
City, state, zip code: Soldier, Ks. 66540

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 10 in. Completion date 5-18-78
Well depth 49 ft. 10" to 20' 8" SD

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material PVC Height: Above or below
Threaded Welded Surface 24 in.
RMP PVC Blue Weight 2.74 lbs./ft.
Dia. 5 in. to 49 ft. depth Wall Thickness: inches or
Dia. in. to ft. depth gage No. 1252

10. Screen: Manufacturer's name Pumped
Type Pvc Dia. 5"
Slot/gauze 090 Length 10'
Set between 15 ft. and 25 ft.
ft. and ft.
Gravel pack? Yes Size range of material 1/4 x 1/8

11. Static water level: 15 ft. below land surface Date 5-18-78 mo./day/yr.

12. Pumping level below land surfaces: Air Test
 ft. after hrs. pumping g.p.m.
 ft. after hrs. pumping g.p.m.
Estimated maximum yield 6 g.p.m.

13. Water sample submitted: mo./day/yr.
Yes No Date

14. Well head completion: Top cap
 Pitless adapter 24 Inches above grade

15. Well grouted? Yes
With: Neat cement Bentonite Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: 200 ft. Direction West Type Laterals
Well disinfected upon completion? Yes No

17. Pump: Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation: 1075
Topography: Hill Slope Upland Valley

19. Remarks: owner to install slab

20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
STRADER DRG Co Inc 182
Business name License No.
Address RT 1 Holtan, Ks
Signed Jake Cell Date 5-22-78
Authorized representative

T
R
W
S
E
N
E
N
E
1/4
1/4
1/4
1/4