

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

ddc

| | | | | | | | |
|---|--|--------------------------------|--------------------------------|--|----------------------------|---|-----------------------------|
| 1 Location of well: | | County JACKSON | Township name BANNER | Fraction SE 1/2 - SE 1/4 | Section number 1 | Town number T7S | Range number R14E |
| Distance and direction from nearest town or city: 3.25 M WEST | | | | 3 Owner of well: DENNIS SCHULTZ | | | |
| Street address of well location if in city: HOLTON, KANS. | | | | Address: RFD 1 HOLTON, KANS. | | | |
| Locate with "X" in section below: | | Sketch map: | | 4 Well depth: 118 ft. Date of completion 4-16-75 Well diameter 5 in. | | | |
| | | | | 5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary | | | |
| | | | | 6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> | | | |
| | | | | 7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. Diam. Weight 2.33 lbs./ft. 5 in. to 118 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | | |
| 2 | | Type and color of material | | From | To | 8 Screen: Manufacturer Pumpco Type PVC Dia. 5" Slot/gauge 0.80 Length 20' Set between 90 ft. and 110 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 4/8 | |
| | | Top Soil | | 0 | 2 | 9 Static water level: Not Measured ____ ft. below land surface Date ____ | |
| | | Yellow Clay | | 2 | 47 | 10 Pumping level below land surfaces: AIR TEST ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 5 g.p.m. | |
| | | Blue Clay | | 47 | 70 | 11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____ | |
| | | SAND | | 70 | 71 | 12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 <input type="checkbox"/> Inches above grade | |
| | | Blue Clay | | 71 | 76 | 13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft. | |
| | | Fine Sand | | 76 | 88 | 14 Nearest source of possible contamination: ft. 200 Direction EAST Type SEPTIC TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| | | Blue Clay | | 88 | 90 | 15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Jacuzzi Bros. Model number 5548 HP 1/2 Volts 230 Length of drop pipe 105 ft. capacity 12 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | |
| | | Coarse Sand | | 90 | 100 | 16 Remarks: elevation 1100 | |
| | | Blue Clay | | 100 | 110 | 17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Drilling Co. Inc. Business name License No. 1182 Address RI-75 N. HOLTON, KANS. Signed Dale Jackson Date 4-20-75 Authorized representative | |
| | | Shale | | 110 | 120 | | |
| | | (use a second sheet if needed) | | | | | |