


15
USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Atchison</u>		Fraction <u>24 1/4 NW 1/4 NW 1/4</u>	Section number <u>24</u>	Township number <u>T 7 S</u>	Range number <u>R 17 E</u>
2. Distance and direction from nearest town or city: <u>3 E 2 1/2</u> Street address of well location if in city: <u>OF ARRINGTON</u>			3. Owner of well: <u>Lloyd Reichart</u> R.R. or street: <u>RT 1</u> City, state, zip code: <u>Valley Falls, KS</u>		
4. Locate with "X" in section below: 			6. Bore hole dia. <u>10</u> in. Completion date <u>8-1-77</u> Well depth <u>60</u> ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>PVC</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. RMP <input type="checkbox"/> PVC <u>9L</u> Weight <u>3.29</u> lbs./ft. Dia. <u>6</u> in. to <u>60</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth Gage No. <u>258</u>		
			10. Screen: Manufacturer's name <u>Pumpco MPT</u> Type <u>PVC</u> Dia. <u>6</u> Gauge <u>.020</u> Length <u>30</u> Set between <u>15</u> ft. and <u>45</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>.030 to .060</u>		
			11. Static water level: <u>10</u> ft. below land surface Date <u>8-1-77</u>		
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>2</u> g.p.m.		
			13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
			14. Well head completion: <u>SAP</u> Pitless adapter <u>24</u> inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
			16. Nearest source of possible contamination: ft. <u>300</u> Direction <u>W</u> Type <u>Creek</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: <u>970'</u> Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: <u>OWNER TO INSTAL SLAB</u>		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Strader Drig Co Inc 182</u> Business name License No. ____ Address <u>Horton, KS</u> Signed <u>Wade Strader</u> Date <u>8-2-77</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5