

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County CLAY	Fraction SE 1/4 SW 1/4 SE 1/4	Section number 10	Township number T 7 S	Range number R 2 E
2. Distance and direction from nearest town or city: 1 1/2 E of MORGANVILLE			3. Owner of well: LAWRENCE ALEXANDER R.R. or street: City, state, zip code: CLIFTON, KS 66937			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 8 in. Completion date 11-16-76 Well depth 48 ft.	
					7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 48 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 24	
5. Type and color of material		From	To	10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5 Slot/gauge 1/16" Length 10' Set between 38 ft. and 48 ft. ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 1/8"		
TOP SOIL + CLAY		0	18	11. Static water level: mo./day/yr. 25 ft. below land surface Date 11-16-76		
SAND		18	23	12. Pumping level below land surfaces: NONE ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 50 g.p.m.		
GRAVEL		23	33	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
GOOD GRAVEL		33	50	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
STOP IN GRAVEL		50		15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 500 Direction EAST Type CREEK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Geo Cox & Sons, Inc 258 Business name License No. Address CLIFTON, KS 66937 Signed Francis Cox Date 12-29 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

258 mnc
7-20-76
10 SE SURVEY

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5