

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County CLAY	Fraction SW 1/4 NW 1/4 NE 1/4	Section number 24	Township number T 7 S R 3 EW
2. Distance and direction from nearest town or city: 2 1/2 WEST			3. Owner of well: BOB MAWHINEY		
Street address of well location if in city: GREEN			R.R. or street: 716 PROSPECT		
			City, state, zip code: CLAY CENTER, KANS 67432		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 4-8-78 Well depth 138 ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 138 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258	
				10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Slot gauze 1/16 Length 20' Set between 118 ft. and 138 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 4x4	
TOPSOIL		0	3	11. Static water level: <input type="checkbox"/> mo./day/yr. 100 ft. below land surface Date 4-8-78	
BROWN CLAY		3	18	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 200 g.p.m.	
BLUE CLAY		18	52	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
BROWN CLAY		52	58	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
LIMESTONE		58	63	15. Well grouted? <input checked="" type="checkbox"/> YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
BROWN CLAY		63	67	16. Nearest source of possible contamination: SEPTIC ft. 200 Direction SOUTH Type TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
BROWN CLAY W/ LIMESTONE		67	78	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
BLUE CLAY		78	95	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DARYL LIXT + SONS INC 359 Business name License No. Address CLIFTON, KANS 66937 Signed Daryl Lixt Date 4-19-78 Authorized representative	
LIMESTONE		95	138		
RED SHALE		138	140		
STOP		140			
		(Use a second sheet if needed)			
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T
7
R
3
W
E
2
4
Sec
1/4
1/4
1/4
1/4
SCANNING