


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Riley		Fraction ONE 1/4 ONE 1/4 ONE 1/4		Section number 15	Township number T 7 S	Range number R 6 E/W
2. Distance and direction from nearest town or city: 1.5 M. N.E. of Randolph				3. Owner of well: John McPherson R.R. or street: City, state, zip code: Randolph Kans 66554		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 8 in. Completion date Nov. 11-79 Well depth 160 ft.		
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From To				9. Casing: Material 1st Height: Above or below Threaded <input type="checkbox"/> Welded 5th Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 160 ft. depth Wall Thickness, inches or Dia. _____ in. to _____ ft. depth gage No. SCF-40		
				10. Screen: Manufacturer's name Pump Co Type PIG Dia. 5" Slot/gauze 1/8 Length 20' Set between 140 ft. and 160 ft. Gravel pack? Yes Size range of material 8-12		
Lime Rock				11. Static water level: _____ mo./day/yr. 130 ft. below land surface Date 11-11-79		
Shale Blue				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Lime Rock White-With Flint				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
" " " " White Clay layers				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Shale Brown				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
" Gray				16. Nearest source of possible contamination: ft. 500 Direction ANY Type Pasture Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Shale Brown				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Lime Rock Gray				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Paul Popidaks 176 Business name _____ License No. _____ Address Popidaks Signed John McPherson 11-11-79 Authorized representative Date		
" " yellow						
" " Gray With Flint Blue						
Shale Blue						
Lime Rock White						
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 7 S R 6 E/W 15 NE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5