

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

| | | | | | |
|--|----------------------|---------------------------------------|---|-------------------------------|--|
| 1. Location of well: | County: <u>Riley</u> | Fraction: <u>NW 1/4 NW 1/4 SW 1/4</u> | Section number: <u>23</u> | Township number: T <u>7</u> S | Range number: R <u>6</u> E/W |
| 2. Distance and direction from nearest town or city: <u>1/2 - N - 1 - E - 3/8 of Randolph, Ks.</u> Street address of well location in city: | | | 3. Owner of well: <u>W. Hans Freienmuth</u> Street: <u>102 N. Main</u> City, state, zip code: <u>Tonganoxie Kans. 66084</u> | | |
| 4. Locate with "X" in section below: N W E S 1 Mile | | | Sketch map: | | |
| 5. Type and color of material | | | From | To | 6. Bore hole dia. <u>8</u> in. Completion date <u>May 1-80</u> Well depth <u>150</u> ft. |
| <u>Clay Brown</u> | | | <u>0</u> | <u>3</u> | 7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary |
| <u>Lime Rock White</u> | | | <u>3</u> | <u>8</u> | 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other |
| <u>Clay Brown</u> | | | <u>8</u> | <u>10</u> | 9. Casing: Material <u>PIST</u> Height: Above <input type="checkbox"/> below <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <u>Clare</u> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>5</u> in. to <u>150</u> ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>Sh. 40</u> |
| <u>Lime Rock White</u> | | | <u>16</u> | <u>20</u> | 10. Screen: Manufacturer's name <u>PUMPLO</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>1/4</u> Length <u>30'</u> Set between <u>120</u> ft. and <u>150</u> ft. ft. and <input type="checkbox"/> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4 - 1/2</u> |
| <u>Clay White</u> | | | <u>20</u> | <u>35</u> | 11. Static water level: <u>70</u> ft. below land surface Date <u>5-1-80</u> mo./day/yr. |
| <u>Lime Rock White</u> | | | <u>35</u> | <u>40</u> | 12. Pumping level below land surfaces: <u>90</u> ft. after <u>4</u> hrs. pumping <u>5</u> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <u>5</u> g.p.m. |
| <u>Clay Yellow</u> | | | <u>40</u> | <u>50</u> | 13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr. |
| <u>Lime Rock White</u> | | | <u>50</u> | <u>70</u> | 14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade |
| <u>Shale Blue</u> | | | <u>70</u> | <u>80</u> | 15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>4</u> ft. to <u>14</u> ft. |
| <u>Lime Rock White With Flint Blue</u> | | | <u>80</u> | <u>110</u> | 16. Nearest source of possible contamination: <u>Hold</u> ft. <u>50</u> Direction <u>S</u> Type <u>Tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| <u>Shale Blue</u> | | | <u>110</u> | <u>120</u> | 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>SPRINT</u> Model number <u>6600625</u> HP <u>1/2</u> Volts <u>230</u> Length of drop pipe <u>170</u> ft. capacity <u>5</u> g.p.m. |
| <u>Shale Blue</u> | | | <u>135</u> | <u>150</u> | Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |
| (Use a second sheet if needed) | | | | | |
| 18. Elevation: | 19. Remarks: | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Blue Rapids Ks. 66411</u> Business name <u>Hargers Drilling Serv.</u> License No. <u>176</u> Address <u>C.E. Harger</u> Date <u>5-1-80</u> Signed <u>C.E. Harger</u> Authorized representative | | |
| Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley | | | | | |

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

7
 R
 W
 23
 Sec
 1/4
 1/4
 1/4