


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

all of Lot # 254 Block #1 of Bridge View Heights, a subdivision located in Riley Co. Kans

WATER WELL RECORD
826-12041215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <i>Riley</i>	Fraction <i>NW 1/4 SW 1/4 NW 1/4</i>	Section number <i>23</i>	Township number <i>7 South</i>	Range number <i>6 E</i>
2. Distance and direction from nearest town or city: Street address of well location in city:		<i>east of Manhattan to first road west of dam 1/4 mile north</i>		3. Owner of well: R. B. or street City, state, zip code: <i>Edison Diller Nebr. City Nebr. 68410</i>		
4. Locate with "X" in section below:		6. Bore hole dia. <i>1 1/2</i> in. Completion date Well depth <i>168</i> <i>7-27-1979</i>			7. <input checked="" type="checkbox"/> Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary	
		8. Use: <input checked="" type="checkbox"/> Domestic ___ Public supply ___ Industry ___ Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other			9. Casing: Material <i>PVC</i> Height: <input checked="" type="radio"/> Above <input type="radio"/> below Threaded ___ Welded ___ Surface ___ in. RMP ___ PVC ___ Weight ___ lbs./ft. Dia. <i>5</i> in. to <i>168</i> ft. depth Wall Thickness: <i>3/16</i> Wall Dia. ___ in. to ___ ft. depth gage No. ___	
5. Type and color of material		From	To	10. Screen: Manufacturer's name <i>Can Tex</i> Type <i>PVC</i> Dia. <i>5</i> in. Slot/gauge <i>.045</i> Length <i>20</i> ft. Set between <i>148</i> ft. and <i>68</i> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <i>1/8 to 1/2"</i>		
<i>top soil Black</i>		<i>0</i>	<i>4</i>	11. Static water level: <i>70</i> ft. below land surface Date <i>7-27-79</i>		
<i>Rock, yellow Lime</i>		<i>4</i>	<i>30</i>	12. Pumping level below land surfaces: ___ ft. after ___ hrs. pumping ___ g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield <i>3</i> g.p.m.		
<i>Clay, yellow</i>		<i>20</i>	<i>29</i>	13. Water sample submitted: <i>NA</i> ___ Yes ___ No Date		
<i>Shale, Red</i>		<i>29</i>	<i>36</i>	14. Well head completion: <i>NA</i> ___ Pitless adapter ___ Inches above grade		
<i>Rock, yellow lime</i>		<i>36</i>	<i>70</i>	15. Well grouted? <input checked="" type="checkbox"/> With: ___ Neat cement ___ Bentonite ___ Concrete Depth: From <i>17</i> ft. to <i>6</i> ft.		
<i>Shale, Blue water</i>		<i>70</i>	<i>130</i>	16. Nearest source of possible contamination: ft. <i>500</i> Direction <i>NE</i> Type <i>ditch</i> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No		
<i>Shale, Red</i>		<i>130</i>	<i>140</i>	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ___ HP ___ Volts ___ Length of drop pipe ___ ft. capacity ___ g.p.m. Type: ___ Submersible ___ Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other.		
<i>Shale, Blue</i>		<i>140</i>	<i>168</i>			
		(Use a second sheet if needed)				
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Strader Drilling Co 237</i> Business name <i>Blue Rapids Mo</i> License No. ___ Address <i>Harold Strader</i> Signed <i>Harold Strader</i> Date <i>7-27-79</i> Authorized representative			

T 7
R 16
Sec 23
NW 1/4
SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5