CORRECTION(S) TO WATER WELL RECORD (WWC-5)
(to rectify lacking or incorrect information)

County: Pottawatomie

Location listed as:	**Location changed to:**
Section-Township-Range: 23 - 7 - 9E	14 - 7S - 9E
Fraction (¼ ¼ ¼): NW NE SW	NW NW NE

Other changes: Initial statements:

Changed to:

Comments:

verification method: County ownership map, and aerial photos on KGS website.

initials: DRL date: 9/14/2005

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726
to: Kansas Dept of Health & Environment, Bureau of Water, 1000 SW Jackson, Suite 420, Topeka, KS 66612-1367.

17

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

NW NE SW

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well: County	Township name	Fraction	Section number	Town number	Range number
Pott.	Rock Creek		23	7	9 E

Distance and direction from nearest town or city: 3 Mi.S.-2 East of Blaine, Ks.

Street address of well location if in city:

3 Owner of well: Argyle Berg

Address: Blaine Kans.

Locate with "X" in section below: Sketch map:

N
W E
S
1 Mile

4 Well depth: 99 ft. Date of completion _____
Well diameter 5' in. 7-3-75

5 ☒ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary

6 Use: ☒ Domestic ☐ Public supply ☐ Industry
☐ Irrigation ☐ Air conditioning ☐ Commercial
☐ Test well ☐ _____

7 Casing: Material PVC Height: above/below
Threaded ☐ Welded ☐ Surface 24 in.
Diam. Weight 200 lbs./ft.
5 in. to 99 ft. depth Drive shoe? ☐ Yes ☒ No
___ in. to ___ ft. depth Well Plug

8 Screen:
Manufacturer Pumpco Special
Type Slotted PVC Dia. 5'
Slot/gauze 30 Length 40'
Set between 59 ft. and ___ ft. 99
Fittings:
Gravel pack ☒ Yes ☐ No Size range of material NO

9 Static water level:
25 ft. below land surface Date 7-3-75

10 Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 10 g.p.m. Bail Test

11 Water sample submitted:
☐ Yes ☒ No Date _____

12 Well head completion:
☐ Pitless adapter N.A. ☐ Inches above grade

13 Well grouted? ☒ Yes ☐ No
☒ Neat cement ☐ Bentonite ☐ _____
Depth: From 4 ft. to 14 ft.

14 Nearest source of possible contamination:
ft. 300 Direction SW Type Septic Tank
Well disinfected upon completion? ☒ Yes ☐ No

15 Pump: ☒ Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.m.p.
Type:
☐ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Certrifugal ☐ Other

2 Type and color of material	From	To
Brown Clay	0	20
Glacer Rock & Sand	20	25
Blue Shale & Wtr. Shale	25	30
Lime Rock & White	30	35
Blue Shale	35	45
Grey Clay - Soft	45	47
Lime Rock	47	52
Lime Rock Grey	52	57
Blue Shale	57	62
Lime Rock & Bl. Shale 2nd. Wtr.	62	67
Lime Rock & Bl. Shale	67	78
Blue Shale	78	83
Blue Shale	83	88
Blue Flint & Lime Rock	88	93
Blue Shale	93	99
(use a second sheet if needed)		

16 Remarks: elevation 1250

Topography:
☐ Hill
☐ Slope
☒ Upland
☐ Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name Harpers Drlg. Service License No.
Address Blue Springs Ks 176
Signed [signature] Date 7-3-75
Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

677-H