

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County CLAY	Fraction SW 1/4 SW 1/4 NE 1/4	Section number 13	Township number T 8 S R	Ronge number 1 (EW)
2. Distance and direction from nearest town or city: IN IDANA			3. Owner of well: JOHN MARSH			
Street address of well location if in city:			R.R. or street: City, state, zip code: IDANA, KANSAS 67453			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 8 in. Completion date 5/2/77 Well depth 60 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 60 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 258	
5. Type and color of material		From	To	10. Screen: Manufacturer's name PILMICO Type PVC Dia. 5" Slot/gauze 1/16 Length 20' Set between 40 ft. and 60 ft. Gravel pack? YES Size range of material 1/4-1/2		
TOPSOIL		0	2	11. Static water level: 23 ft. below land surface Date 5/2/77 mo./day/yr.		
BROWN CLAY		2	18	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after 1 1/2 hrs. pumping ____ g.p.m. Estimated maximum yield 2 g.p.m.		
SANDY CLAY		18	36	13. Water sample submitted: ____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date		
BLUE SHALE		36	52	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
6 1/2'		52	60	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
STOP		60		16. Nearest source of possible contamination: SEPTIC ft. 95 Direction SOUTH Type TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. GEO LOY & SONS INC. 258 Business name License No. _____ Address ELIOTON, KANS 66937 Signed [Signature] Date 5/2/77 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 8
 R 1
 W (EW)
 Sec 13
 1/4 1/4 1/4 1/4