

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Pottawatomie	Fraction SE 1/4 NE 1/4 NW 1/4	Section number 4	Township number T 8 S R 11 E/W	Range number
2. Distance and direction from nearest town or city: 6 1/2 S 1 1/2 W			3. Owner of well: Joe Ballentine			
Street address of well location if in city: Onaga, Ks.			R.R. or street: RTI			
			City, state, zip code: ONAGA, KANS.			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date _____		
				Well depth 96 ft. 12-19-77		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC blue Weight 2.24 lbs./ft. Dia. 5 in. to 96 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .258		
5. Type and color of material		From	To	10. Screen: Manufacturer's name _____		
Top Soil		0	1	Type PVC Dia. 5"		
Brown Shale		1	7	Slot gauze 020 Length 20'		
Brown Limestone		7	8	Set between 40 ft. and 50 ft.		
Brown Shale		8	23	80 ft. and 90 ft.		
Black Shale		23	25	Gravel pack? Yes Size range of materials 0.30x0.60		
Gray Shale		25	44	11. Static water level: _____ mo./day/yr.		
Gray Sandstone		44	48	12 ft. below land surface Date 12-19-77		
Gray Sandy Shale		48	64	12. Pumping level below land surfaces: Art test		
Gray limestone		64	65	_____ ft. after _____ hrs. pumping _____ g.p.m.		
Gray Shale		65	69	_____ ft. after _____ hrs. pumping _____ g.p.m.		
Gray Sandy Shale		69	71	Estimated maximum yield 10 g.p.m.		
Red Shale		71	80	13. Water sample submitted: _____ mo./day/yr.		
Gray Sandstone		80	87	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Gray Shale		87	100	14. Well head completion: Top casing		
				Pitless adapter 24 inches above grade		
				15. Well grouted? Yes		
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
				Depth: From 5 ft. to 15 ft.		
				16. Nearest source of possible contamination:		
				ft. 100 Direction S Type Laterals		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed		
				Manufacturer's name _____		
				Model number _____ HP _____ Volts _____		
				Length of drop pipe _____ ft. capacity _____ g.p.m.		
				Type:		
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks: owner to pour slab		20. Water well contractor's certification:		
Topography:				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
<input type="checkbox"/> Hill				Stander Dalg Co Inc 182		
<input checked="" type="checkbox"/> Slope				Business name _____ License No. _____		
<input type="checkbox"/> Upland				Address RTI Hallway, Ks		
<input type="checkbox"/> Valley				Signed Dale Askew Date 12-21-77		
				Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5