

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County POTTAWATOMIE	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 10	Township number T 8 S R 12 E/W	Range number
2. Distance and direction from nearest town or city: 3.7 N OF EMMETT			3. Owner of well: Thom Rezac R.R. or street: RR City, state, zip code: EMMETT, KS 66422		
4. Locate with "X" in section below:			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 8-22-79 Well depth 75 ft.
Top Soil			0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay, brown			3	22	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Shale, grey, red, blk.			22	59	9. Casing: Material PVC Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC 9L Weight 2182 lbs./ft. Dia. 5 in. to 75 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250
Limestone, yellow, water bearing			59	63	10. Screen: Manufacturer's name Pumpco Type PVC Dia. 5 Slot/gauze .020 Length 25 Set between 50 ft. and 75 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material .030x.060
Shale, grey			63	75	11. Static water level: <input type="checkbox"/> mo./day/yr. 50 ft. below land surface Date 8-22-79
					12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 15 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.
					14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 29 Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: 200 ft. Direction E Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
			(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	owner to install slab		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER Dalg W 192 Business name _____ License No. _____ Address Holtan, KS Signed Dale Asher Date 8-23-79 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5