

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

cdd

1. Location of well: County Jackson Fraction SW 1/4 SE 1/4 SW 1/4 Section number 4 Township number T 8 S R 15 Range number EW			
2. Distance and direction from nearest town or city: Street address of well location if in city:		3. Owner of well: Gibson, Theodore R.R. or street: Rural Route City, state, zip code: Mayetta, Kansas	
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 	
5. Type and color of material		6. Bore hole dia. 10 in. Completion date 6/29/76 Well depth 45 ft.	
		7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
		9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 41 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 13 lbs./ft. Dia 8 in. to 25 ft. depth Wall Thickness: inches or Dia 8 in. to 45 ft. depth gage No. 188	
		10. Screen: Manufacturer's name Steel Pipe Supply Type Steel Dia. 6 1/2" Slot/gauze 1/2" holes Length 8 1/4 Set between 2 1/2 ft. and 2 1/2 ft. ft. and 1 1/2 ft. Gravel pack? Yes Size range of material 2"	
		11. Static water level: 5 ft. below land surface Date 6/29/76 mo./day/yr.	
		12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 13 g.p.m.	
		13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____	
		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter ____ inches above grade	
		15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.	
		16. Nearest source of possible contamination: ft. 30 Direction North Type pond Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: 1155 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		19. Remarks: Slab to be installed by customer. He knows this is a regulation.	
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cummings Drilling Co 148 Business name License No. Address 110 Apple St Signature Lawrence Cummings Date 8/3/76 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment.

Form WWC-5

1155
1150
1128
1119

1-8
 R 150
 Sec 4
 SW SE SW