

41

15 VBRT

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

bdd

WATER WELL RECORD
KSA 82a-1201-1215

add (see sketch: airphoto K65)

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Jefferson		Fraction SE NW SE 1/4 SW 1/4 NE 1/4		Section number 4	Township number T 8 S R	Range number 19 20
2. Distance and direction from nearest town or city: 2 1/2 S 1 1/2 E			3. Owner of well: David Aspinwall			
Street address of well location if in city: Nortonville, Ks.			R.R. or street: RR1			
			City, state, zip code: Nortonville, Ks. 66660			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 12-21-78		
				Well depth 100 ft.		
7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug		<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry		<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock				
<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		9. Casing: Material pvc Height: Above or below				
Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 36 in.		RMP <input type="checkbox"/> PVC Blue Weight 2.74 lbs./ft.				
Dia. 5 in. to 100 ft. depth		Wall Thickness: inches or				
Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth		gauge No. 1257				
5. Type and color of material		From	To	10. Screen: Manufacturer's name PUMPRO		
Top Soil		0	2	Type pvc Dia. 5"		
Brown Clay		2	24	Sieve gauze 020 Length 20'		
Tan & Rusty Clay		24	40	Set between 75 ft. and 95 ft.		
Brown Silty Clay		40	43	ft. and <input type="checkbox"/> ft.		
Yellow Fine Sandy Clay		43	48	Gravel pack? Yes Size range of material 030/060		
Yellow Fine Sand		48	58	11. Static water level: <input type="checkbox"/> mo./day/yr.		
Tan Silty Clay		58	66	60 ft. below land surface Date 12-21-78		
Yellow Med Sand		66	70	12. Pumping level below land surfaces: Air Test		
Gray Clay		70	78	<input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.		
Gray Med. Gravel & Cherty		78	91	<input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.		
Gray Shale		91	100	Estimated maximum yield 50 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr.		
				Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
				14. Well head completion: Top Cap		
				<input type="checkbox"/> Pitless adapter 36 Inches above grade		
				15. Well grouted? Yes		
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
				Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: 19. Roads		
				ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/>		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed		
				Manufacturer's name <input type="checkbox"/>		
				Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/>		
				Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m.		
				Type:		
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 11252		19. Remarks: owner to install slab		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill		16. New home site in open field		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
<input type="checkbox"/> Slope				STRADER Drly. Co 182		
<input checked="" type="checkbox"/> Upland				Business name <input type="checkbox"/> License No.		
<input type="checkbox"/> Valley				Address RT 1 Holton, Ks.		
				Signed Chas Rayen Date 12-28-78		
				Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR elev = 1054 - 1031
V = 1034

P
A

190
4
SE
NE
NW
SW