

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

X Location of well:		County <u>Clay</u>	Fraction <u>SW 1/4 SW 1/4 NE 1/4</u>	Section number <u>12</u>	Township number <u>8</u>	Range number <u>32 E</u>
X Distance and direction from nearest town or city: <u>3/4 W of Clay Center</u>		3. Owner of well: <u>Hooke Farms, Inc</u>		City, state, zip code: <u>Clay Center, Kansas 67432</u>		
Street address of well location if in city:		4. Locate with "X" in section below:		Sketch map:		
		5. Type and color of material		From	To	6. Bore hole dia. <u>32</u> in. Completion date <u>4-19-74</u> Well depth <u>54</u> ft.
		<u>top soil + clay</u>		<u>0</u>	<u>28</u>	7. <u> </u> Cable tool <u> </u> Rotary <u> </u> Driven <u> </u> Dug <u> </u> Hollow rod <u> </u> Jetted <u> </u> Bored <u>X</u> Reverse rotary
		<u>good gravel</u>		<u>28</u>	<u>32</u>	8. Use: <u> </u> Domestic <u> </u> Public supply <u> </u> Industry <u>X</u> Irrigation <u> </u> Air conditioning <u> </u> Stock <u> </u> Lawn <u> </u> Oil field water <u> </u> Other
		<u>shale</u>				9. Casing: Material <u>AC</u> Height: Above <u> </u> or below <u> </u> Threaded <u> </u> Welded <u> </u> Surface <u>12</u> in. RMP <u> </u> PVC <u> </u> Weight <u>34</u> lbs./ft. Dia. <u>16</u> in. to <u>54</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u>
		<u>sand + gravel</u>		<u>28</u>	<u>32</u>	10. Screen: Manufacturer's name <u>Johnson</u> Type <u>Transit</u> Dia. <u>16</u> Slot/gauge <u>1/8</u> Length <u>26</u> Set between <u>28</u> ft. and <u>54</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>YES</u> Size range of material <u>1/8-1/4</u>
		<u>good gravel</u>		<u>32</u>	<u>54</u>	11. Static water level: <u> </u> mo./day/yr. <u>30</u> ft. below land surface Date <u>7-11-77</u>
		<u>shale</u>				12. Pumping level below land surfaces: <u>52</u> ft. after <u>1/2</u> hrs. pumping <u>1100</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1100</u> g.p.m.
						13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <u>X</u> No Date <u> </u>
						14. Well head completion: <u> </u> Pitless adapter <u>12</u> Inches above grade
						15. Well grouted? <u>YES</u> NO With: <u> </u> Neat cement <u> </u> Bentonite <u>X</u> concrete Depth: From <u> </u> ft. to <u>20</u> ft. <u>0-10</u>
						16. Nearest source of possible contamination: <u>NONE</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <u> </u> Yes <u>X</u> No
						17. Pump: <u> </u> Not installed Manufacturer's name <u>WLR</u> Model number <u>8M</u> HP <u>30</u> Volts <u>230</u> Length of drop pipe <u>45</u> ft. capacity <u>1000</u> g.p.m. Type: <u> </u> Submersible <u>X</u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other
18. Elevation:		19. Remarks: <u>After 2 weeks pumping, well drops to between 700 gpm + 750 gpm. we've tried gate valve + will probably install a smaller pump. Problems not solved yet. Report filed anyway</u>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>For L & S Inc</u> <u>258</u> Business name <u>Clifton, Kansas</u> License No. <u> </u> Address <u> </u> Signed <u>Francis L &</u> Date <u>7-11</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

2-28-78

Form WWC-5