

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Clay	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 19	Township number T 8 S R 3 E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:		1 South of Clay Center Mark Oliphant R.R. or street: City, state, zip code: Clay Center, Kansas 66432			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>6</u> in. Completion date <u>8/3/79</u> Well depth <u>112</u> ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <u>PVC</u> Height: Above <u>ground</u> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>3</u> lbs./ft. Dia. <u>5</u> in. to <u>112</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth <u> </u> <u>258</u>	
				10. Screen: Manufacturer's name <u>Pumpco Supply</u> Type <u>PVC</u> Dia. <u>5</u> Slot <u>1/16</u> Length <u>20</u> Set between <u>92</u> ft. and <u>112</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8 - 1/4</u>	
				11. Static water level: <u>60</u> ft. below land surface Date <u>8/3/79</u> mo./day/yr.	
				12. Pumping level below land surfaces: <u>110</u> ft. after <u>1 1/2</u> hrs. pumping <u>5</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>5</u> g.p.m.	
				13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade	
				15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
				16. Nearest source of possible contamination: <u>None</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks:			20. Water well contractor's certification:	
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	Well didn't produce enough water and may be used as secondary well			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cox - Beswick <u>361</u> Business name License No. Address <u>Clifton, Kansas 66937</u> Signed <u>Juanis Cox</u> Date <u>9-1-79</u> Authorized representative	

T-8
 R-3
 W-19
 Sec-19
 NE 1/4
 NE 1/4
 NE 1/4