


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| | |
|---|---|
| 1. Location of well: County CLAY Fraction SW 1/4 SE 1/4 SW 1/4 Section number 24 Township number T 8 S R 3 Range number 3 | |
| 2. Distance and direction from nearest town or city: 3 E-2 S Street address of well location if in city: CLAY CENTER | |
| 3. Owner of well: EVERETT ZAISS R.R. or street: ROUTE 3 City, state, zip code: CLAY CENTER 69432 | |
| 4. Locate with "X" in section below:  | 6. Bore hole dia. 5" in. Completion date 8-5-16-79 Well depth 110 ft. |
| | 7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary |
| 5. Type and color of material | 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other |
| | 9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2 lbs./ft. Dia. 5 in. to 110 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258 |
| | 10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Slot/gauze 1/16 Length 20' Set between 90 ft. and 110 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 4x4 |
| | 11. Static water level: <input type="checkbox"/> mo./day/yr. 60 ft. below land surface Date 5-16-79 |
| | 12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after 1 1/2 hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 30 g.p.m. |
| | 13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/> |
| | 14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade |
| | 15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. |
| | 16. Nearest source of possible contamination: ft. 100 Direction EAST Type LOTS Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| | 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |
| (Use a second sheet if needed) | |
| 18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley | 19. Remarks: 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DARREN COX & SONS INC 359 Business name _____ License No. _____ Address CLAYTON KANS 66937 Signed Daryl Cox Date 5-16-79 Authorized representative |

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5