

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

To Leonard
4-26-77

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Pott		Fraction SE 1/4 SE 1/4 NW 1/4		Section number 35		Township number Green T 8 S R 7 EW		Range number			
2. Distance and direction from nearest town or city: 9 miles SE of Oldsberg, Kansas				3. Owner of well: Living Water Ranch							
Street address of well location if in city:				R.R. or street: Rt 1							
				City, state, zip code: Oldsberg Kansas							
4. Locate with "X" in section below:				Sketch map:				6. Bore hole dia: 12 in. Completion date 6-76 Well depth 105 ft.			
								7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
								8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
								9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded Blue Surface 24 in. RMP <input checked="" type="checkbox"/> PVC Weight 200 lbs./ft. Dia. 5 in. to 105 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 716			
5. Type and color of material				From		To		10. Screen: Manufacturer's name Sunflower Type 200 Dia. 5" Slot/gauze 716 Length 30 Set between 30 ft. and 105 ft. ft. and ft. Gravel pack? Yes Size range of material 1/4-1/2			
Top Soil				0		5		11. Static water level: 30 ft. below land surface Date 6-1-76 mo./day/yr.			
Clay - light Brown				5		10		12. Pumping level below land surface: 100 ft. after 17 hrs. pumping 15 g.p.m. 50 ft. after 3 hrs. pumping 7 g.p.m. Estimated maximum yield 7 g.p.m.			
Limestone				10		20		13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
Gray Clay				20		31		14. Well head completion: <input checked="" type="checkbox"/> Pitless 24" inches above grade			
Limestone				32		41		15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 20 ft. to 5 ft.			
Light Gray Clay				42		66		16. Nearest source of possible contamination: Drain Field ft. 350 Direction NE Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Limestone				67		88		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Light Gray Clay				89		95					
Limestone				96		105					
(Use a second sheet if needed)											
18. Elevation:		19. Remarks: The Septic Tank and Lotterols May Be Further Away Than I Stated, Because They Were Not Installed at the time we left, M.D.L.				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Leptich Bros. 329 Business name Box 58 Miltonvale License No. Address Mark D. Leptich Date 3-27-76 Signed Mark D. Leptich Authorized representative					
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley											

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5