

28

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD KSA 82a-1201-1215

Kansas State Dept. Of Health (Water Well Contractors) Forbes-Bldg. 740 Topeka, Kansas 66620

Well # 1

SE NE NW

1 Location of well:		County Pottawatomie	Township name 8 NE-SE 1/4 of NW 1/4	Fraction	Section number 28	Town number 8	Range number 8E
Distance and direction from nearest town or city:				3 Owner of well: Milton Anderson			
Street address of well location if in city:				Address: Anderson Realty 103 S. 8th Manhattan, Kans.			
Locate with "X" in section below:		Sketch map:		4 Well depth: 83 ft. Date of completion 6/25/75 Well diameter 8 in.			
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well			
				7 Casing: Material RMP Height: above *** Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. Diam. 5 1/8 Weight 200 lbs./ft. ___ in. to ___ ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth!			
2		Type and color of material	From	To	8 Screen:		
		Top soil	0	2	Manufacturer Western Plastics		
		Rock & flint	2	8	Type RMP Dia. 5"		
		Clay	8	11	Slot/gauze 3/32 Length 2 1/2"		
		Rock	11	15	Set between 63 ft. and 83 ft.		
		Blue	15	31	Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/16 to 3/8		
		Limestone & flint	31	41	9 Static water level: 49 ft. below land surface Date 6/25/75		
		Shale	41	50	10 Pumping level below land surfaces: ___ ft. after ___ hrs. pumping ___ g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 16 g.p.m.		
		Rock	50	53	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date capped		
		Shale	53	56	12 Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade		
		Hollow rock	56	61	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ___ Depth: From 0 ft. to 10 ft.		
		Shale	61	67	14 Nearest source of possible contamination: none ft. ___ Direction ___ Type ___ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
		Rock	67	83	15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ___ Model number ___ HP ___ Volts ___ Length of drop pipe ___ ft. capacity ___ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation				17 Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		385'		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rader Drilling Co. 194 Business name License No. Address Carlton, Kans. 67429 Signed Grant P. Rader Date 7-29-75 Authorized representative			