



USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

NE SE SE

1 Location of well:	County POTAWATOMIE	Township name WAMEGO	Fraction NW 1/2	Section number 32	Town number 9	Range number 10 E	
Distance and direction from nearest town or city: 1/2 W - 1 mi N of Wamego, Kans.			3 Owner of well: DANE WILSON				
Street address of well location if in city: RR II WAMEGO			Address: RR II WAMEGO				
Locate with "X" in section below: N  S E W			Sketch map: 	75' 75' X	4 Well depth: 120 ft. Date of completion 1-29-75 Well diameter 10 in.		
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			TOP soil	0	5	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
			yellow clay	5	30	7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. Diam. Weight 233 lbs./ft. 5 in. to 120 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth	
			Brown Sandy Clay	30	80	8 Screen: Manufacturer PUMP CO Type PVC Dia. 5" Slot/gauge 60 Length 10' Set between 107 ft. and 117 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material #3	
			COURSE Sand	80	90	9 Static water level: 80 ft. below land surface Date 1-29-75	
			COURSE Sand-medium gravel	90	117	10 Pumping level below land surfaces: Air Test ___ ft. after ___ hrs. pumping ___ g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 30 g.p.m.	
			117 - Blue Shale	117	120	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___	
						12 Well head completion: CAPPED <input type="checkbox"/> Pitless adapter 24 <input type="checkbox"/> Inches above grade	
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.	
						14 Nearest source of possible contamination: ft. 200 Direction WEST Type SEPTIC TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
			15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
16 Remarks: elevation 117' Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Drilling Co. Inc. #182 Business name _____ License No. _____ Address RR I - N 75 Holton, KANS. Signed Dale Baker Date 2-4-75 Authorized representative				