

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pottawatomie	Fraction near ctr, of 1/4 1/4 NW 1/4	Section number 34	Township number T 9S S R 11E E/W	Range number
2. Distance and direction from nearest town or city: $\frac{1}{2}$ mi. No. & $\frac{1}{8}$ mi. West of Belvue, Ks. Street address of well location if in city:			3. Owner of well: Carl R. Fulmer R.R. or street: City, state, zip code: Belvue, Kansas 66407		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. <u>30</u> in. Completion date <u>10-30-78</u> Well depth <u>61</u> ft.
Black soil			0	3	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Hard brown silt			3	22	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Med. brown gravel & brown silt			22	24	9. Casing: Material <u>Trans.</u> Height (Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12"</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. <u>16</u> in. to <u>35</u> ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. <u>75"</u>
Soft gray silt			24	31	10. Screen: Manufacturer's name <u>Johnson Well Co.</u> Type <u>Transite</u> Dia. <u>16"</u> Slot/auze <u>1/8x8</u> Length <u>26'</u> Set/between <u>35'</u> ft. and <u>61'</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>5/8</u>
Med. gray gravel & gray silt			31	33	11. Static water level: _____ mo./day/yr. <u>17</u> ft. below land surface Date <u>8-28-78</u>
Fine gray sand & gray silt			33	36	12. Pumping level below land surfaces: <u>37</u> ft. after <u>1</u> hrs. pumping <u>1000</u> g.p.m. <u>45</u> ft. after <u>3</u> hrs. pumping <u>1200</u> g.p.m. Estimated maximum yield <u>1300</u> g.p.m.
Med. to large gray gravel & gray silt			36	37	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Small to med. gray gravel & gray silt			37	39	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
Med. to large gray gravel & gray silt			39	42	15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
Med. to large gray gravel			42	48	16. Nearest source of possible contamination: ft. <u>600</u> Direction <u>south</u> Type <u>road ditch</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Small to med. gray gravel			48	50	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Med. to large brown gravel			50	61	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hoobler Drilling Co. 323 Business name License No. Address <u>St. Marys, Ks. 66536</u> Signed <u>[Signature]</u> Date <u>11-28-78</u> Authorized representative
Stopped.			61		
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					

T 9
 R 11
 W 34
 Sec 34
 1/4 1/4 1/4
 C MW
 78