

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

SE 1/4 SW 1/4

1. Location of well:	County <u>POTAWATOMIE</u>	Fraction <u>SE 1/4 SE 1/4 SE 1/4</u>	Section number <u>2</u>	Township number <u>T 9</u>	Range number <u>S R 12 E/W</u>
2. Distance and direction from nearest town or city: <u>1 S - 1 E . 3 W</u>		3. Owner of well: <u>Roy Smith</u>			
Street address of well location if in city: <u>OF EMMETT</u>		R.R. or street: City, state, zip code: <u>ST. MARYS</u>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>10</u> in. Completion date _____ Well depth <u>40</u> ft. <u>9-6-77</u>	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material <u>PVC</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>29</u> in. RMP <input type="checkbox"/> PVC <u>9L</u> Weight <u>2.58</u> lbs./ft. Dia. <u>5</u> in. to <u>40</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>258</u>	
				10. Screen: Manufacturer's name _____ <u>Pumpco</u> Type <u>PVC</u> Dia. <u>5</u> Slot/gauze <u>.020</u> Length <u>20</u> Set between <u>20</u> ft. and <u>40</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>10x100</u>	
<u>TOP SOIL</u>		<u>0</u>	<u>6</u>	11. Static water level: _____ mo./day/yr. <u>23</u> ft. below land surface Date <u>4-6-77</u>	
<u>Clay, BROWN</u>		<u>6</u>	<u>23</u>	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>5</u> g.p.m.	
<u>GRAVEL</u>		<u>23</u>	<u>26</u>	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
<u>Shale, grey</u>		<u>26</u>	<u>40</u>	14. Well head completion: <u>CAP</u> <input type="checkbox"/> Pitless adapter <u>29</u> inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>20</u> ft.	
				16. Nearest source of possible contamination: ft. <u>100</u> Direction <u>S</u> Type <u>DRAINAGE</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Stanley Deha Co Inc 182</u> Business name _____ License No. _____ Address <u>RT 1 Holton, KS</u> Signed <u>Dale Robinson</u> Date <u>4-8-77</u> Authorized representative	
18. Elevation: <u>1000</u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		19. Remarks: <u>OWNER WITH INSTAL SLAB</u>			

T 9 S R 12 E/W Sec 2 SE 1/4 SW 1/4