

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County CLAY	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 22	Township number T 9 S R	Range number 20 EW
2. Distance and direction from nearest town or city: 9 S 2 W			3. Owner of well: DAVID BLOOMBERG		
Street address of well location if in city: 1/2 N CLAY CENTER			R.R. or street: RFD		
			City, state, zip code: CLAY CENTER, KANS 67432		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 8-21-78	
				Well depth 119 ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
TOPSOIL		0	3	9. Casing: Material PVC Height: Above or below	
BROWN CLAY		3	65	Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in.	
GRAY CLAY		65	73	RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft.	
BROWN CLAY		73	82	Dia 5 in. to 119 ft. depth Wall Thickness: inches or	
LIMESTONE		82	86	Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258	
BLUE SHALE		86	105	10. Screen: Manufacturer's name PUMPCO	
LIMESTONE		105	113	Type PVC Dia. 5"	
BLUE SHALE		111	120	Slot/gauze 1/16 Length 20'	
STOP		120		Set between 100 ft. and 120 ft.	
				Gravel pack? YES Size range of material 4x4	
				11. Static water level: 50 ft. below land surface Date 8-21-78	
				12. Pumping level below land surfaces:	
				ft. after N/A hrs. pumping <input type="checkbox"/> g.p.m.	
				ft. after N/A hrs. pumping <input type="checkbox"/> g.p.m.	
				Estimated maximum yield 107 g.p.m.	
				13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date	
				14. Well head completion: 12 inches above grade	
				15. Well grouted? YES	
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete	
				Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: SEPIK	
				ft. 75 Direction NORTH Type TANK	
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed	
				Manufacturer's name	
				Model number HP Volts	
				Length of drop pipe ft. capacity g.p.m.	
				Type:	
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:	
Topography:				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
<input type="checkbox"/> Hill				DARYL COX & SONS INC 359	
<input type="checkbox"/> Slope				Business name License No.	
<input checked="" type="checkbox"/> Upland				Address CLIFTON, KANS 66937	
<input type="checkbox"/> Valley				Signed Daryl Cox Date 8-21-78	
				Authorized representative	

T
R
W
E
S
E
N
E
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5