

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Jefferson	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 29	Township number T 9 S R 20 E W	Range number
2. Distance and direction from nearest town or city: 3 mi. N.			3. Owner of well: Phillip Cline			
Street address of well location if in city: McClouth			R.R. or street: RR			
			City, state, zip code: McLouth, KS.			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 7 7/8 in. Completion date 5-19-78		
				Well depth 155 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below 24 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC GLAC Weight 2.74 lbs./ft. Dia. 5 in. to 155 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 1258		
5. Type and color of material		From	To	10. Screen: Manufacturer's name Pumped		
Top Soil		0	1	Type PVC Dia. 5"		
Brown Clay		1	6	Slab gauze .000 Length 30"		
Brown Sandy Clay		6	27	Set between 15 ft. and 35 ft. 70 ft. and 80 ft.		
Gray Clay		27	75	Gravel pack? yes Size range of material .075/.060		
Gray Cherty Clay		75	80	11. Static water level: 15 ft. below land surface Date 5-14-78		
Brown & Gray Shale & limestone		80	155	12. Pumping level below land surfaces: Air Test		
				____ ft. after ____ hrs. pumping ____ g.p.m.		
				____ ft. after ____ hrs. pumping ____ g.p.m.		
				Estimated maximum yield 1.5 g.p.m.		
				13. Water sample submitted: ____ mo./day/yr.		
				Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date ____		
				14. Well head completion: Top cap		
				____ Pitless adapter 24 Inches above grade		
				15. Well grouted? yes		
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
				Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 200 Direction SW Type lotents		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed		
				Manufacturer's name ____		
				Model number ____ HP ____ Volts ____		
				Length of drop pipe ____ ft. capacity ____ g.p.m.		
				Type:		
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		owner to install slab		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
				STRADER Dalg Co Inc 182		
				Business name License No.		
				Address RT 1 Holton, KS		
				Signed Dale Ashen Date 5-17-78		
				Authorized representative		

T 9 R 20 S 29 NE NE SW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5