

47

VPRT

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

abb

1. Location of well: County <u>Jefferson</u>		Fraction <u>NW</u> SW <u>1/4 NW 1/4 NE 1/4</u>		Section number <u>29</u>		Township number <u>T 9 S R 20</u>		Range number <u>E/W</u>			
2. Distance and direction from nearest town or city: <u>3 N</u>				3. Owner of well: <u>Delbert Brunk</u>							
Street address of well location if in city: <u>McLouth</u>				R.R. or street: <u>RR</u>							
				City, state, zip code: <u>McLouth, Ks. 66054</u>							
4. Locate with "X" in section below:				Sketch map:				6. Bore hole dia. <u>8</u> in. Completion date <u>5-29-79</u> Well depth <u>150</u> ft.			
								7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				9. Casing: Material <u>PVC</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. RMP <input type="checkbox"/> PVC <u>Blue</u> Weight <u>2.74</u> lbs./ft. Dia. <u>5</u> in. to <u>150</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <u>1258</u>			
5. Type and color of material				From		To		10. Screen: Manufacturer's name <u>PUMPCO MPI</u> Type <u>PVC</u> Dia. <u>5"</u> Slot gauge <u>.080</u> Length <u>60</u> Set between <u>40</u> ft. and <u>100</u> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <u>Yes</u> Size range of material <u>4x1/8</u>			
<u>Yellow Clay</u>				<u>0</u>		<u>23</u>		11. Static water level: <u>40</u> ft. below land surface Date <u>5-29-79</u> mo./day/yr.			
<u>Brown Limestone</u>				<u>23</u>		<u>25</u>		12. Pumping level below land surfaces: <u>Air test</u> <u>16</u> ft. after <u>1</u> hrs. pumping <u>12</u> g.p.m. <u>12</u> ft. after <u>1</u> hrs. pumping <u>12</u> g.p.m. Estimated maximum yield <u>12</u> g.p.m.			
<u>Brown Shale</u>				<u>25</u>		<u>30</u>		13. Water sample submitted: <u>12</u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
<u>Gray Shale</u>				<u>30</u>		<u>68</u>		14. Well head completion: <u>Top Cap</u> <u>24</u> Inches above grade <input type="checkbox"/> Pitless adapter			
<u>Gray Shale & Limestone</u>				<u>68</u>		<u>150</u>		15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
								16. Nearest source of possible contamination: ft. <u>200</u> Direction <u>NW</u> Type <u>Lester</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
								17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <u>182</u> HP <u>1/2</u> Volts <u>115</u> Length of drop pipe <u>10</u> ft. capacity <u>12</u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
								20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>STRADER DRILLING Co Inc 182</u> Business name License No. Address <u>871 Hollen, Ks</u> Signed <u>Delbert Brunk</u> Date <u>6-30-79</u> Authorized representative			
18. Elevation: <u>1060</u> <u>58</u>		19. Remarks: <u>owner to install slab</u>									
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley											

T 9 R 20 S 29 E
SW 1/4 NE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR also = 1035