

46

VBRT

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

Jefferson

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

acb

1. Location of well:		County McClouth Jefferson	Fraction N 1/4 S 1/4 NE 1/4	Section number 8	Township number T 9 S	Range number R 20 E
2. Distance and direction from nearest town or city: 5 and 5/8 miles North of McClouth, Kansas			3. Owner of well: BOB VERNON R.R. or street: #2 McClouth, KS. 66054 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map: septic			6. Bore hole dia. 8 in. Completion date 9-17-77 Well depth 150 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stack <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
SURFACE		0	2	9. Casing: Material _____ Height: Above or below _____ Threaded _____ Welded _____ Surface 1.2 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 150 ft. depth, Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 3/16		
DRIFT		2	35	10. Screen: Manufacturer's name _____ Type _____ Dia. _____ Slot/gauze _____ Length _____ Set between _____ ft. and _____ ft. Gravel pack? YES Size range of material 1/4" x 1/8"		
SHALE		35	37	11. Static water level: _____ mo./day/yr. 25 ft. below land surface Date 9/17/77		
BLACK SLATE		37	38	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.		
LIME		38	42	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
SHALE		42	46	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
LIME		46	51	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 15 ft.		
SHALE		51	60	16. Nearest source of possible contamination: _____ ft. 75 Direction North Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
SANDSTONE		60	90	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
LIME		90	115	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. A.C. GLAZE-DRILLING 350 Business name _____ License No. _____ Address 121 S. Cluster 1st St. McClouth, KS Signed Phyllis H. Glaze Date 10/21/77 Authorized representative		
SHALE		115	147			
BLACK SLATE		147	150			
TOTAL DEPTH			150			
(Use a second sheet if needed)						
18. Elevation: 1037 1030 Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: Customer is aware of State regulations and agrees to install a 4' square reinforced concrete platform around top of well. Bob Vernon				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BTR elev = 975

10152