


ck Fa

not found 6180

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Leavenworth	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 2	Township number T 9 S 5 R 21	Range number 21
2. Distance and direction from nearest town or city: 4 1/4 miles west of Leavenworth, Ks. on 92 Hwy.		3. Owner of well: Geer Construction Company R.R. or street: 7315 State City, state, zip code: Kansas City, Kansas			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 8 in. Completion date 6-10-78 Well depth: 100 ft.	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
NO. 6				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top Soil		0	1	9. Casing: Material PL. Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 102 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. .265	
Clay		1	12	10. Screen: Manufacturer's name (Slotted Pipe) Vinylplex, Inc. Type PVC Dia. 5" Slot/gauze .06 1/16 Length 5' Set between 15 ft. and 20 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 1/8	
Sand & Clay		12	20	11. Static water level: _____ mo./day/yr. 6 ft. below land surface Date 6-10-78	
Clay (Soft in Spots)		20	38	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 8 g.p.m.	
Lime (Black)		38	42	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Shale (Blue)		42	67	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade	
Lime		67	78	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.	
Shale		78	82	16. Nearest source of possible contamination: ft. 400 Direction NE Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Lime		82	96	17. Pump: Not installed Manufacturer's name K Jacuzzi Model number 5S4B HP 1/2 Volts 220 Length of drop pipe 90 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Shale		96	100	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BREUER, INC. 174 Business name License No. Address Box 147, Basehor, Ks. Signed <i>[Signature]</i> Date 6-22	
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

(Use a second sheet if needed)

9
21
2
SW
NE
NW
SE