

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Leavenworth	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 34	Township number 9	Range number 21E
2. Distance and direction from nearest town or city: 1 3/4 mile NE of Jarbalo			3. Owner of well: Joe Immell		
Street address of well location if in city:			R.R. or street: Rt. 1 Box 205		
			City, state, zip code: Leavenworth, Kans. 66048		
4. Locate with "X" in section below:		Sketch map:			
		<p>6. Bore hole dia. 6 3/4 in. Completion date 5/15/79 Well depth 80 ft.</p> <p>7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material _____ Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 4 1/2 _____ PVC _____ Weight 1.3 lbs./ft. Dia. 4 1/2 in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Sch. No. 200</p>			
5. Type and color of material		From	To		
surface		0	2		
clay (yellow)		2	32		
clay (sandy)		32	34		
clay (blue)		34	54		
sand and gravel		54	64		
shale (sandy, grey)		64	80		
					10. Screens: Manufacturer's name _____ Johnson Type plastic Dia. 4 1/2 Slot size .018 Length 5' Set between 55 ft. and 60 ft. Gravel pack? yes Size range of material builders' sand
					11. Static water level: _____ mo./day/yr. 30 ft. below land surface Date 5/15/79
					12. Pumping level below land surfaces: 55 ft. after 1 hrs. pumping 12 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 12 g.p.m.
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 13 ft. to 3 ft.
					16. Nearest source of possible contamination: ft. 800 Direction west Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: _____ Not installed Manufacturer's name Gould's Model number 10EJ HP 1/2 Volts 230 Length of drop pipe 70 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other
18. Elevation: 930		19. Remarks: Customer is aware of state regulation and agrees to install a 4' square re-enforced concrete platform around top of well.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. F. E. Young Drilling Co., Inc. 240 Business name 6355 Robinhood Ln. License No. _____ Address _____ Signed David Young Date 6/19/79 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5