USE TYPEWRHER C	R BALL
POINT PEN-PRESS	FIRMLY,
PRINT CLEARLY.	4

## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

				Topeka, Kansas addzo
County Fraction X	7	Section r		Township number Range number
Leavenworth Leavenworth NE 1/4 NE 1/4 SE	S 1/4	35	5	T 9 S R 21 (E)W
2. Distriptor and direction from needest town or city: 2 miles east and itreet address of well-location if in city: 1 mile north of Jaroal Kansas	R.R. or	er of well: street: ate, zip c		Mr. Park Blaine Route 1 Moorhead, Iowa
4. Locate with "X" in section below: Sketch map:	1			6. Bore hole dia. 8 in. Completion date 2-8-17 Well depth 150 ft.
NW NE				7 Cable tool x Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary
W				8. Use: X Domestic Public supply Industry Irrigation Air conditioning Stock Lawn Oil field water Other
sw se				9. Casing: Material PL. Height: Above or below Threaded Welded X Surface
S I <del>→ 1</del> Mile ————————————————————————————————————				RMPPVCXWeightlbs./ft Dia5in. toStrt. depth!Wall Thickness: Incheslbs./ft
. Type and color of material		From	То	Diain. toft. depth gage No
Top Soil		0	15	Type PVC Dia 5"
Silt & Gravel		15	24	Slot/gauze 06 1/16 Length 9 ft. Set between 20 ft. and 29 ft.
Sandstone		24	29	Gravel pack? X Size range of material 78.
Blue Shale		29	76	11. Static water level:  17 ft, below land surface Date 2-8-77
<b>7</b> ₿ Sandy Shale		76	88	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m.
Shale		88	150	ft. after hrs. pumping g.p.m.  Estimated maximum yield g.p.m.
				13. Water sample submitted: mo./day/yr.  Yes X No Date
		<u> </u>		14. Well head completion:
			_	15. Well grouted? Yes
			With: X Neat cement Bentonite Concrete Depth: From 3 ft. to 6t.	
			16. Negrest source of possible contamination: ft. 000 Direction SE Type Septic	
			Well disinfected upon completion? X Yes No  17. Pump: Not installed	
			Manufacturer's name Jacuzzi  Model number 75/18 HP 3/11 Volts 220	
			Length of drop pipe 145 ft. capacity 10g.p.m.	
				Submersible Turbine Reciprocating
(Use a second sheet if needed)				Centrifugal Other
8. Elevation: 19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report
[□□□ Topography:				is true to the best of my knowledge and belief.  BREUER, INC. 174
Hill Slope				Business name BOX 147 Basehor, Ks. 6000
Upland Valley				Signed Authorized representative
orward the white, blue and pink copies to the Department of Health and Environment				Form WWC-5

BR elaw = 906= 913