

1 LOCATION OF WATER WELL
 County: CLAY Fraction SE 1/4 SW 1/4 SW 1/4 Section Number 18 Township Number T 9 S Range Number R 3 EW

Distance and direction from nearest town or city? 8 SOUTH 7/8 W CLAY CENTER Street address of well if located within city?

2 WATER WELL OWNER: ROBERT CARLSON
 RR#, St. Address, Box #: CLAY CENTER, KANSAS 67432 Board of Agriculture, Division of Water Resources
 City, State, ZIP Code: CLAY CENTER, KANSAS 67432 Application Number:

3 DEPTH OF COMPLETED WELL: 120 ft. Bore Hole Diameter: 8 in. to 120 ft., and in. to ft.
 Well Water to be used as:
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 Well's static water level: 60 ft. below land surface measured on month 9 day 7 year 79
 Pump Test Data: Well water was NA ft. after hours pumping gpm
 Est. Yield 10 gpm: Well water was NA ft. after hours pumping gpm

4 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped
 2 PVC 4 ABS 7 Fiberglass 9 Other (specify below) Welded
 Blank casing dia: 5 in. to 100 ft., Dia in. to ft., Dia in. to ft.
 Casing height above land surface: 12 in., weight lbs./ft. Wall thickness or gauge No
 TYPE OF SCREEN OR PERFORATION MATERIAL:
 7 PVC 10 Asbestos-cement
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)
 Screen or Perforation Openings Are:
 8 Saw cut 11 None (open hole)
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 6 Wire wrapped 9 Drilled holes
 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)
 Screen-Perforation Dia: 5 in. to 120 ft., Dia in. to ft., Dia in. to ft.
 Screen-Perforated Intervals: From 100 ft. to 130 ft., From ft. to ft.
 Gravel Pack Intervals: From 14 ft. to 120 ft., From ft. to ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grouted Intervals: From 4 ft. to 14 ft., From ft. to ft., From ft. to ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)
 Direction from well: EAST How many feet: 150? Water Well Disinfected? Yes No
 Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample
 was submitted month day year Pump Installed? Yes No
 If Yes: Pump Manufacturer's name Model No. HP Volts
 Depth of Pump Intake ft. Pumps Capacity rated at gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was
 completed on month 9 day 7 year 79
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 359
 This Water Well Record was completed on month 11 day 29 year 79 under the business
 name of DARYL COX & SONS INC. by (signature) Daryl Cox

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
	0	3	TOPSOIL	120		STOP
	3	37	BROWN CLAY			
	37	38	RED CLAY			
	38	42	GRAY CLAY			
	42	46	LIMESTONE			
	46	59	BLUE CLAY			
	59	60	LIMESTONE			
	60	66	BLUE CLAY			
	66	85	RED CLAY			
	85	99	LIMESTONE			
ELEVATION:	99	120	BLUE SHALE			

Depth(s) Groundwater Encountered 1. 60 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY
T
R
EW
SEC
SE 1/4 SW 1/4 SW 1/4