

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County CLAY	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 34	Township number T 9 S	Range number R 4 E E/W
2. Distance and direction from nearest town or city: 3 1/2 MI. E WAKEFIELD 1 NORTH Street address of well location if in city:			3. Owner of well: MELVIN CROWDER R.R. or street: 1117 PROSPECT City, state, zip code: SALINA, KS. 67401		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 10-17-78 Well depth 108 ft.
TOPSOIL			0	10	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
RED CLAY			10	24	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
GREY CLAY BUFF ROCK			24	28	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 2 1/2 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight 200 lbs./ft. Dia. 5 in. to 10 1/8 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200
LIMESTONE			28	38	10. Screen: Manufacturer's name JESS & LOWELL Type SLOT Dia. 5" Slot/gauze 1/8 Length 5 1/2 30' Set between 78 ft. and 108 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/4 1/2
LIMESTONE CAVITY (LOSS OF CIRCULATION)					11. Static water level: _____ mo./day/yr. 84 ft. below land surface Date 10-17-78
TOTAL DEPTH				108	12. Pumping level below land surfaces: 84 ft. after 1 hrs. pumping 15 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
					14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.
					16. 2 MI. nearest source of possible contamination: LAKE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PESTINGER DRILLING 328 Business address SALINA, KS. License No. _____ Address _____ Signed <i>Steve Pestinger</i> Date 10/19/78 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 9
 R 4 E
 Sec 34 NW SE NW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5