

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

LOT # 4

1. Location of well:		County Riley	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 36	Township number T 9	Range number S R 6 E/W
2. Distance and direction from nearest town or city: .4 W			3. Owner of well: JACK NEEF			
Street address of well location if in city: OF KEATS			R.R. or street: City, state, zip code: MANHATTAN			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 8 in. Completion date Well depth 120 ft. 7-6-76	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP PVC 9L Weight 3.58 lbs./ft. Dia. 5 in. to 120 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 374	
					10. Screen: Manufacturer's name Pumpco Type PVC Dia. 5 Slot/gauze .060 Length 20 Set between 60 ft. and 90 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/8	
					11. Static water level: <input type="checkbox"/> mo./day/yr. 60 ft. below land surface Date 7-6-76	
					12. Pumping level below land surfaces: AIR TEST ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 15 g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
					14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24 inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.	
					16. Nearest source of possible contamination: ft. 100 Direction E Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:			20. Water well contractor's certification:	
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		OWNER WILL INSTALL SLAB			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER DRG. CO INC 182 Business name License No. Address RT 1 HOLTON, KS Signed Wade Astum Date 7-9-76 Authorized representative	

9
 60
 36
 NW 1/4
 NW 1/4
 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5