

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 826-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

LOT #2

1. Location of well:		County Riley	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 36	Township number T 9 S	Range number R 6 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
.3 NW OF KEATS			JACK NEEF RRI MANHATTAN, Ks.			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>8</u> in. Completion date Well depth <u>120</u> ft. <u>7-8-76</u>	
					7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <u>PVC</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. RMP <u>PVC 7L</u> Weight <u>2.58</u> lbs./ft. Dia. <u>5</u> in. to <u>120</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>2124</u>	
					10. Screen: Manufacturer's name <u>PUMPCO</u> Type <u>PVC</u> Dia. <u>5</u> <u>56</u> gauge <u>.060</u> Length <u>20</u> Set between <u>55</u> ft. and <u>75</u> ft. ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 X 1/8</u>	
					11. Static water level: <u>56</u> ft. below land surface Date <u>7-7-76</u> mo./day/yr.	
					12. Pumping level below land surfaces: <u>AIR TEST</u> <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>15</u> g.p.m.	
					13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>	
					14. Well head completion: <u>CAP</u> <input type="checkbox"/> Pitless adapter <u>24</u> inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>5</u> ft. to <u>15</u> ft.	
					16. Nearest source of possible contamination: ft. <u>150</u> Direction <u>SE</u> Type <u>SEPTIC</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:			20. Water well contractor's certification:	
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		(Use a second sheet if needed) OWNER WILL INSTAL SLAB			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>STRADER Dalg. Co., Inc 182</u> Business name <u> </u> License No. <u> </u> Address <u>RTI Holton, Ks</u> Signed <u>Dale Ashwin</u> Date <u>7-9-76</u> Authorized representative	

2
 60
 36
 NW 1/4 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5