

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County RILEY	Fraction SE 1/4 SE 1/4 NW 1/4	Section number 9	Township number T 9 S R 7 E/W	Range number
2. Distance and direction from nearest town or city: 5 1/2 mi. NW OF MANHATTAN KS.			3. Owner of well: LEON MCLUGIN R.R. or street: 618 MORO City, state, zip code: MANHATTAN, KS, 66502			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 8 in. Completion date 3-16-83 Well depth 112 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material					9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC 9L Weight 283 lbs./ft. Dia. 5 in. to 112 ft. depth Well Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 258	
		From	To	10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Slot/gauze 80 Length 70 FT. Set between 52 ft. and 62 ft. 80 ft. and 90 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 in.		
RED CLAY		1	26	11. Static water level: _____ mo./day/yr. 50 ft. below land surface Date 3-16-83		
WHITE ROCK		26	31	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 64 GPM g.p.m.		
GREEN SHALE		31	40	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
GREEN AND RED CLAY		40	52	14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24" inches above grade		
YELLOW ROCK (LITTLE WATER)		52	56	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 6 ft. to 18 ft.		
GREEN CLAY		56	62	16. Nearest source of possible contamination: ft. 150 Direction EAST Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
YELLOW ROCK		62	68	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
YELLOW CLAY		68	74	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. RAY ENSLEY DRILLING 202 Business name _____ License No. _____ Address RT. 6 MANHATTAN Signed Ray Ensley Date 3-16-83 Authorized representative		
YELLOW ROCK		74	76			
GREEN SHALE		76	81			
YELLOW ROCK (MORE WATER)		81	85			
GRAY SHALE		85	90			
GRAY ROCK		90	94			
BLUE SHALE		94	112			
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5