

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Riley	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 17	Township number T 9 0	Range number R 7 0 W
2. Distance and direction from nearest town or city: 1.7 N 1.5 E			3. Owner of well: DR. J. T. PETERSON			
Street address of well location if in city: 2.5 N OF HEATS			R.R. or street: City, state, zip code: RR4 BOX 194 MANHATTAN, KS 66502			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date _____ Well depth 100 ft. 11-30-78		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
TOP SOIL		0	4	9. Casing: Material PVC Height: 66 or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in. RMP <input type="checkbox"/> PVC 9/16 Weight 250 lbs./ft. 2.82 Dia. 5 in. to 100 ft. depth Wall Thickness: inches or 2.58 Dia. _____ in. to _____ ft. depth gage No. 279		
Clay, BROWN		4	29	10. Screen: Manufacturer's name Pumpco MRI Type PVC Dia. 5 10 gauze .060 Length 70 Set between 60 ft. and 100 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 1/8		
Limestone, yellow		29	37	11. Static water level: _____ mo./day/yr. 60 ft. below land surface Date 11-30-78		
Shale, yellow, Red, Black		37	70	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.		
Limestone, yellow, soft, water bearing		70	75	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Shale, grey, Limestone, grey		75	100	14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24 Inches above grade		
(Use a second sheet if needed)				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
18. Elevation:		19. Remarks:		16. Nearest source of possible contamination: ft. 300 Direction S Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		OWNER TO INSTALL SLAB		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Shaden Drilling Co 182 Business name License No. _____ Address RT1 Holton, Kas. Signed Dale Pookun Date 12-4-78 Authorized representative		

T-9
 R-70
 W-0
 Sec-17
 SESESE
 1/4 1/4 1/4