

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County POCAHONTAS	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 18	Township number T 9 S 8 E	Range number 8 E
2. Distance and direction from nearest town or city: 4.5 N of				3. Owner of well: SULLIVAN ASSOC.		
Street address of well location if in city: MANHATTAN				R.R. or street: 1010 WESTLOP PL		
				City, state, zip code: MANHATTAN, KANS. 66502		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 12 in. Completion date 3-2-79		
		NO CONTAMINATION IN SEVERAL THOUSAND FEET		Well depth 250 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug		
				<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry		
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock		
				<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: 24 or below		
				Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in.		
				RMP <input type="checkbox"/> PVC 9L Weight 4.02 lbs./ft.		
				Dia. 6 in. to 250 ft. depth Wall Thickness: inches or		
				Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 316		
5. Type and color of material		From	To	10. Screen: Manufacturer's name PUMCO MPI		
Clay, brown		0	3	Type PVC Dia. 6		
Shale, yellow, Red		3	53	Slot gauge 1060 Length 80		
Limestone, yellow		53	74	Set between 170 ft. and 250 ft.		
Shale, yellow, red		74	125	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 1/8		
Shaley Lime, grey		125	165	11. Static water level: 170 ft. below land surface Date 3-2-79		
Shale grey, black		165	196	12. Pumping level below land surfaces:		
Limestone, yellow, water bearing		196	200	____ ft. after ____ hrs. pumping ____ g.p.m.		
Shaley Limestone, grey		200	237	____ ft. after ____ hrs. pumping ____ g.p.m.		
Limestone, grey		237	240	Estimated maximum yield 60 g.p.m.		
Shale, grey		240	250	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date ____		
				14. Well head completion: 24 inches above grade		
				____ Pitless adapter		
				15. Well grouted? <input checked="" type="checkbox"/>		
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
				Depth: From 5 ft. to 25 ft.		
				16. Nearest source of possible contamination:		
				ft. NONE Direction X Type X		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed		
				Manufacturer's name ____		
				Model number ____ HP ____ Volts ____		
				Length of drop pipe ____ ft. capacity ____ g.p.m.		
				Type:		
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill		6x6 slab will be const.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
<input type="checkbox"/> Slope				Strader Delg Co Inc 182		
<input type="checkbox"/> Upland				Business name		
<input type="checkbox"/> Valley				Address RT 1 Holton, KS License No. ____		
				Signed Dale Robinson Date 3-2-79		
				Authorized representative		