

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Pottawatomie</u>	Fraction <u>SE 1/4 NE 1/4 SE 1/4</u>	Section number <u>24</u>	Township number T <u>9</u> S R	Range number <u>8</u> EW
2. Distance and direction from nearest town or city: <u>4 N 2 W</u>			3. Owner of well: <u>Gary Honeycut</u>			
Street address of well location if in city: <u>St. George</u>			R.R. or street: <u>RR.</u>			
			City, state, zip code: <u>St. George, KS</u>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date <u>10-5-77</u>		
				Well depth <u>120</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>PVC</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. RMP <u>PVC Blue</u> Weight <u>2.74</u> lbs./ft. Dia. <u>5</u> in. to <u>120</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>1258</u>		
5. Type and color of material		From	To	10. Screen: Manufacturer's name <u>Pumpco</u> Type <u>PVC</u> Dia. <u>5"</u> Gauge <u>280</u> Length <u>25</u> Set between <u>25</u> ft. and <u>100</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>4x8</u>		
<u>Fill</u>	<u>0 1</u>	<u>Yellow limestone</u>	<u>57</u>	<u>62</u>	11. Static water level: <u>70</u> ft. below land surface Date <u>10-5-77</u>	
<u>Tan Shaley L.S.</u>	<u>1 3</u>	<u>Gray Shale</u>	<u>62</u>	<u>71</u>	12. Pumping level below land surfaces: <u>Alt. Test</u> <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>6</u> g.p.m.	
<u>Tan Limestone</u>	<u>3 15</u>	<u>Tan Shale</u>	<u>71</u>	<u>80</u>	13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
<u>Tan Shale</u>	<u>15 18</u>	<u>Tan Limestone</u>	<u>80</u>	<u>85</u>	14. Well head completion: <u>Top Cap</u> <input type="checkbox"/> Pitless adapter <u>24</u> Inches above grade	
<u>Lt Gray Shaley L.S.</u>	<u>18 21</u>	<u>Yellow Gray L.S.</u>	<u>85</u>	<u>92</u>	15. Well grouted? <u>YES</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
<u>Tan-Gray Shale</u>	<u>21 23</u>	<u>Tan Limestone</u>	<u>92</u>	<u>93</u>	16. Nearest source of possible contamination: ft. <u>200</u> Direction <u>SE</u> Type <u>laterals</u> Well disinfected upon completion? <u>YES</u> Yes <input type="checkbox"/> No <input type="checkbox"/>	
<u>Tan L.S., Shaley</u>	<u>23 26</u>	<u>Lt. Gray limestone</u>	<u>93</u>	<u>101</u>	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
<u>Gray Shale</u>	<u>26 27</u>	<u>Gray Shale</u>	<u>101</u>	<u>103</u>		
<u>Tan Limestone</u>	<u>27 32</u>	<u>Black Shale</u>	<u>103</u>	<u>104</u>		
<u>Gray Shale</u>	<u>32 37</u>	<u>Gray limestone</u>	<u>104</u>	<u>120</u>		
<u>Tan limestone</u>	<u>37 41</u>					
<u>Tan shale</u>	<u>41 47</u>					
<u>Tan limestone</u>	<u>47 49</u>					
<u>Brown Shale</u>	<u>49 52</u>					
<u>Tan Shale</u>	<u>52 57</u>					
(Use a second sheet if needed)						
18. Elevation:	19. Remarks: <u>owner to pour cement slab,</u>			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>STRADER DR19 Co</u> <u>182</u> Business name License No. Address <u>Holtan, KS</u> Signed <u>Dale Ashburn</u> Date <u>10-10-77</u> Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T-9
 R-8
 W-24
 SE
 NESE
 Sec 24 SE NESE 1/4 1/4 1/4