

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County POTTAWATOMIE	Fraction SE SE SE NE 1/4 NE 1/4 NE 1/4	Section number 9	Township number T 9 S R 9	Range number 9
2. Distance and direction from nearest town or city: .5 S 1 E			3. Owner of well: Fred EBERT		
Street address of well location if in city: of Flush			R.R. or street: RRT		
			City, state, zip code: ST. GEORGE, KS,		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date _____	
				Well depth 60 ft. 8-2-77	
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material PVC Height: 60 or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in. RMP <input type="checkbox"/> PVC 9L Weight 2.58 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 258	
5. Type and color of material		From	To	10. Screen: Manufacturer's name PUMPCO MPE	
TOP SOIL		0	9	Type PVC Dia. 5	
Clay, Brown		9	43	Flow gauze .020 Length 30	
GRAVEL		43	46	Set between 40 ft. and 60 ft.	
Shale, Grey		46	60	Gravel pack? <input checked="" type="checkbox"/> Size range of material 10/30 x 60	
				11. Static water level: _____ mo./day/yr. 40 ft. below land surface Date 8-2-77	
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 15 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
				14. Well head completion: CAD <input type="checkbox"/> Pitless adapter 24 Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bestonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. 300 Direction W Type Creek Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STANDER Dalg Co Inc Business name _____ License No. _____ Address 4010 W, KS Signed Dale Ashen Date 8-4-77 Authorized representative	
18. Elevation: 1098		19. Remarks: OWNER TO INSTAL SLAB			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5