


37

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Pottawatomie	Township name St. George	Fraction ^{SW} SE 1/4 / SE 1/4	Section number 29	Town number T9S	Range number R9E
Distance and direction from nearest town or city: 2 3/4 mi. N. of St. George, Ks			3 Owner of well: Rural Water District No. 1 Pottawatomie Co., Ks. 1005 Pine Wamego, Ks 66547			
Street address of well location if in city:			Address:			
Locate with "X" in section below: N 			Sketch map:			4 Well depth: 173 ft. Date of completion 1-31-75 Well diameter 22 in.
2 Type and color of material			From		To	
			Top Soil		0 2	
			Brown Clay		2 7	
			Red Clay		7 20	
			Fine Sand		20 57	
			Sandy Clay		57 80	
			Clay w/ some Sand		80 145	
			Blue Sandy Clay		145 150	
			Fine to Coarse Sand w/ Clay		150 154	
			Medium to Coarse Sand & Gravel w/ Rocks (Hard)		154 173	
Blue Shale		173 176				
(use a second sheet if needed)					5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					6 Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
					7 Casing: Material Steel Height: above/ below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 30 in. Diam. 10 in. to 158 ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 10 in. to 158 ft. depth! Weight 24.24 lbs./ft.	
					8 Screen: Manufacturer Cook Type Wire Wrap Dia. 10" Slot/gauze 70 Length 15' Set between 158 ft. and 173 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material ---	
					9 Static water level: 85.6 ft. below land surface Date 2-12-75	
					10 Pumping level below land surfaces: 108 ft. after 24 hrs. pumping 250 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
					12 Well head completion: 30 <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 20 ft.	
					14 Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Jacuzzi Model number 8MS HP 30 Volts 480 Length of drop pipe 130 ft. capacity 250 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation East Well - "B" 1182 Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Snyder Weston Co 102 Business name _____ License No. _____ Address Wichita Kansas Signed [Signature] Date 2/25/75 Authorized representative	