

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Pottawatomie		County: Pottawatomie	Fraction: NW 1/4 NW 1/4 NE 1/4	Section number: 30	Township number: 9 S	Range number: 9 E
2. Distance and direction from nearest town or city: Flush 4 mi So Street address of well location if in city: 1/2 mi West		3. Owner of well: Dan Westgate R.R. or street: R-1 City, state, zip code: St George Kans 66535		4. Locate with "X" in section below		
		Sketch map:		6. Bore hole dia. 12 in. Completion date: 7-18-78 Well depth 69 ft.		
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Rock, Blue Flint		0	5	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Shale, Blue		5	20	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 69 ft. depth Wall Thickness: 3/16 Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 269 Well		
Rock, yellow Limestone		20	49	10. Screen: Manufacturer's name MPI Type PVC Dia. 5 Slot/gage 040 Length 20 Set between 59 ft. and 39 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 1/4		
Shale, Blue Hard		49	69	11. Static water level: 43 ft. below land surface Date 7-18-78 mo./day/yr.		
				12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 12 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: NA <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> 1-2 With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 15 ft. to 5 ft.		
				16. Nearest source of possible contamination: 500 ft. Direction North Type Creek Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Drilling Co 237 1/4 Business name Blue Rapids 113 license No. Address Harold Strader Signed Harold Strader Date 7-18-78 Authorized representative		

East of PM
 9 S
 9 E
 30
 NW 1/4 NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5