

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Osborne	Fraction N.W 1/4 NW 1/4 Se 1/4	Section number 22	Township number T 10 S S R 15	Range number E/W
2. Distance and direction from nearest town or city: 3 miles S.E. of Natoma Street address of well location if in city:			3. Owner of well: Lawrence Koelling R.R. or street: Paradise, Kansas 67658 City, state, zip code:		
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>Sketch map:</p> </div> <div> <p>Well is about 200' East of dwelling</p> </div> </div>			6. Bore hole dia. 4 1/2 in. Completion date 4/10/78 Well depth 48 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other		
			9. Casing: Material PVC Height: Above or Below 4 1/2 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC 6 in. Weight 2 lbs./ft. Dia. 6 in. to 48 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
			10. Screen: Manufacturer's name _____ Type 1/8" slots Dia. 6 in. Slot/gauze _____ Length 10 ft. Set between 23 ft. and 43 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes size range of material CMA #1 to 1/8"		
			11. Static water level: _____ mo./day/yr. 19 ft. below land surface Date 4/10		
(Use a second sheet if needed)			12. Pumping level below land surfaces: 19 ft. after 3 hrs. pumping 18 g.p.m. 19 ft. after 4 hrs. pumping 18 g.p.m. Estimated maximum yield 40 g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 14 ft. to 4 ft.		
			16. Nearest source of possible contamination: ft. 50 Direction South Type corral Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rush Water Well Service 310 Business name _____ License No. _____ Address Natoma, Kansas 67651 Signed Cesar Rush Date 5/5/78 Authorized representative		
			18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		
			19. Remarks: Well is on level ground about 50' from cattle corral Owner agrees to run burv		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5