


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County <u>ROOK</u>		Fraction <u>NW 1/4 NE 1/4 NW 1/4</u>		Section number <u>19</u>		Township number <u>T 10</u>		Range number <u>S R 19</u>		E/W	
2. Distance and direction from nearest town or city: <u>4 S - 2 3/4 W of ZURICH, KS.</u>				3. Owner of well: <u>HENRY BERLAND</u> R.R. or street: <u>Box 17</u> City, state, zip code: <u>PAICO, KS. 67657</u>							
4. Locate with "X" in section below: 				Sketch map: <u>House</u> <u>Well</u> <u>Lot</u> <u>TTTT</u>		6. Bore hole dia. <u>9</u> in. Completion date <u>1-26-76</u> Well depth <u>102</u> ft.		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material				From	To	9. Casing: Material <u>PVC</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>102</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>200</u>					
<u>BLACK DIRT</u>				<u>0</u>	<u>15</u>	10. Screen: Manufacturer's name <u>Jesse Lowell</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>1/8</u> Length <u>10'</u> Set between <u>92</u> ft. and <u>102</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>1/8 to 1/4</u>					
<u>CLAY</u>				<u>15</u>	<u>55</u>	11. Static water level: _____ mo./day/yr. <u>20</u> ft. below land surface Date <u>1-26-76</u>					
<u>SAND + CLAY</u>				<u>55</u>	<u>78</u>	12. Pumping level below land surfaces: <u>20</u> ft. after <u>1</u> hrs. pumping <u>35</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>60</u> g.p.m.					
<u>FINE SAND</u>				<u>78</u>	<u>90</u>	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____					
<u>Water Bearing SAND</u>				<u>90</u>	<u>102</u>	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>18</u> Inches above grade					
<u>shale</u>						15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>50</u> ft. to <u>10</u> ft.					
						16. Nearest source of possible contamination: ft. <u>50</u> Direction <u>S</u> Type <u>septic tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Paul Dill</u> Business name _____ License No. _____ Address _____ Signed <u>Paul Dill</u> Date <u>3-9-76</u> Authorized representative					
18. Elevation:		19. Remarks: <u>LAND OWNER WAS GOING TO COMPLETE WELL.</u>									
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley											

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 10 R 19 E 19 Sec 19