

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CCB

1. Location of well: County Rooks		Fraction NW¹/₄ SW¹/₄ SW¹/₄		Section number 4		Township number T 10 S		Range number R 20 E	
2. Distance and direction from nearest town or city: 2 1/2 miles South of Palco, Ks.				3. Owner of well: RUSSELL TOWNS					
Street address of well location if in city:				R.R. or street: R.R.					
				City, state, zip code: PALCO, KS. 67657					
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 8/26/77					
		Owell 100' N.E. CORRAL		Well depth 29 ft.					
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug					
				<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry					
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock					
				<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
				9. Casing: Material PST Height: Above or below					
				Threaded <input type="checkbox"/> Welded 9/16 Surface 18 in.					
				RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft.					
				Dia. 5 in. to 29 ft. depth Wall Thickness: inches or					
				Dia. _____ in. to _____ ft. depth gage No. 250					
5. Type and color of material				10. Screen: Manufacturer's name Jess & Lowell					
CLAY		From 0 To 15		Type PLASTIC Dia. 5"					
SAND		15 25		Slot/gauze 1/16 Length 10'					
SHALE		25 29		Set between 19 ft. and 29 ft.					
				_____ ft. and _____ ft.					
				Gravel pack? yes Size range of material 1/4-5/8"					
				11. Static water level: _____ mo./day/yr.					
				14 ft. below land surface Date 8/26/77					
				12. Pumping level below land surfaces: NOT PUMPED					
				_____ ft. after _____ hrs. pumping _____ g.p.m.					
				_____ ft. after _____ hrs. pumping _____ g.p.m.					
				Estimated maximum yield _____ g.p.m.					
				13. Water sample submitted: _____ mo./day/yr.					
				Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____					
				14. Well head completion: NOT DONE					
				<input type="checkbox"/> Pitless adapter _____ inches above grade					
				15. Well grouted? yes					
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete					
				Depth: From 3 ft. to 12 ft.					
				16. Nearest source of possible contamination:					
				ft. 100' Direction N.E. Type CORRAL					
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
				17. Pump: <input checked="" type="checkbox"/> Not installed					
				Manufacturer's name _____					
				Model number _____ HP _____ Volts _____					
				Length of drop pipe _____ ft. capacity _____ g.p.m.					
				Type:					
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine					
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating					
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation: 2200				20. Water well contractor's certification:					
Topography: Topo				This well was drilled under my jurisdiction and this report					
<input type="checkbox"/> Hill				is true to the best of my knowledge and belief.					
<input checked="" type="checkbox"/> Slope				D. & R. Drilling Co 303					
<input type="checkbox"/> Upland				Business name 303 License No. _____					
<input type="checkbox"/> Valley				Address Hall City, Mo. 67642					
19. Remarks: Concrete slab to be run by customer at ground surface.				Signed Allen Corn Date 10-24-77					
				Authorized representative					

T 10 S R 20 E
 Sec 4
 NW 1/4
 NE 1/4
 SE 1/4
 SW 1/4