

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County ROOKS	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 32	Township number T 10 S	Range number R 20 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Melvin Keller R.R. or street: Box 56 City, state, zip code: PAICO, KANSAS			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 9 in. Completion date 3-10-76 Well depth 24 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. <input checked="" type="checkbox"/> Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP: PVC Weight 200 lbs./ft. Dia. 5 in. to 24 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <input type="checkbox"/>		
				10. Screen: Manufacturer's name Jesse Lowell Type PVC Dia. 5" Slot/gauze 1/8 Length 10' Set between 24 ft. and 14 ft. <input type="checkbox"/> Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 1/4		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 9 ft. below land surface Date 3-10-76		
				12. Pumping level below land surfaces: 11 ft. after 4 hrs. pumping 20 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 30 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 14 Inches above grade		
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 12 ft. to 0 ft.		
				16. Nearest source of possible contamination: ft. 2000 Direction South Type oil wells Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Fairbanks Model number <input type="checkbox"/> HP 1 Volts 230 Length of drop pipe 16 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		We set A Pump house over well. Mr Keller is going to run A cement Floor in Pump house		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Paul Kelly Drilling 269A Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box 42 Signed Paul Kelly Date 3/24/76 Authorized representative		

T 10
 R 20
 E
 Sec 32
 SW SW SW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5