

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DAB


1. Location of well: County Sheridan Section AD 1/4 NE 1/4 SE 1/4 Section number 20 Township number T 10 Range number S R 29 E/W

3. Owner of well: Sylvester Holzmeister
R.R. or street: Grinnell, Kansas 67738
City, state, zip code:

X Distance and direction from nearest town or city: 12 mi. South
of Sequin.
Street address of well location if in city: NA

4. Locate with "X" in section below:

Sketch map:



6. Bore hole dia. 8 in. Completion date 4/14/76
Well depth 80 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material plastic Height: Above or below
Threaded Welded GI Surface 15 in.
RMP PVC Weight _____ lbs./ft.
Dia. 5 in. to 80 ft. depth Wall Thickness: inches or
Dia. _____ in. to _____ ft. depth gage No. 032

5. Type and color of material	From	To
Top Soil	0	17
Sandy Clay	17	45
Sand	45	52
Clay	52	65
Sand	65	80
BROCK ?		
(Use a second sheet if needed)		

10. Screen: Manufacturer's name J and L

Type RMP Dia. 5"
Slot/gauze 1/32" Length 2'
Set between 60 ft. and 80 ft.
_____ ft. and _____ ft.
Gravel pack? Yes Size range of material 1/8"

11. Static water level: _____ mo./day/yr.
114 ft. below land surface Date 4/14/76

X Pumping level below land surfaces:
44 ft. after 15 hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield _____ g.p.m.

13. Water sample submitted: _____ mo./day/yr.
Yes No Date _____

14. Well head completion:
NO Pitless adapter _____ Inches above grade

15. Well grouted? yes
With: Neat cement Bentonite Concrete
Depth: From 4 ft. to 18 ft.

16. Nearest source of possible contamination:
ft. _____ Direction none Type _____
Well disinfected upon completion? _____ Yes _____ No

17. Pump: Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation:

Topography:
 Hill
 Slope
 Upland
 Valley

19. Remarks:
This is a windmill well.

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Bartell Drilling 139
Business name License No.
Address Winona, Kansas 67761
Signed Jayce Bartell Date 4/15/76
Authorized representative

10 290-20 NUWNESE