

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County OTTAWA	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 18	Township number T 10 S R 3 E W	Ronge number
2. Distance and direction from nearest town or city: 3 1/2 NORTH			3. Owner of well: MARK M'HENRY			
Street address of well location if in city: MINNEAPOLIS			R.R. or street: ROUTE 3			
			City, state, zip code: MINNEAPOLIS, KANS 67467			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 4-12-79		
				Well depth 155 ft. 4-12-79		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
TOPSOIL		0	3	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12" in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 155 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 1258		
BROWN CLAY		3	8	10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Slot gauze 1/16" Length 20' Set between 135 ft. and 155 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 4x4		
GRAY CLAY		8	10	11. Static water level: <input type="checkbox"/> mo./day/yr. 30 ft. below land surface Date 4-12-79		
SANDROCK		10	17	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after NA pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 60+ g.p.m.		
RED CLAY		17	24	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date		
SANDROCK		24	32	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
BLUE CLAY		32	54	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
RED CLAY		54	68	16. Nearest source of possible contamination: SEWAGE TANK ft. 100 Direction SEWAGE TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
SANDROCK		113	154	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
BLUE CLAY		154	160			
STOP		160				
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DARYL Cox + Sons Inc 359 Business name License No. Address CLIFTON, KANS 66937 Signed Daryl Cox Date 4-25-79 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T
R
W
E
S
10
3
18
MINNEAPOLIS

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5