

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County OTTOWA	Fraction NE 1/4 SW 1/4 SW 1/4	Section number 22	Township number T 10 S R 3 EW	Range number
2. Distance and direction from nearest town or city: 2 E 2 N			3. Owner of well: CURTIS CROSSON			
Street address of well location if in city: MINNEAPOLIS			R.R. or street: ROUTE 2			
			City, state, zip code: MINNEAPOLIS, KANS 67467			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date		
				Well depth 80 ft. 8/19/77		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below 0 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 80 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258		
5. Type and color of material		From	To	10. Screen: Manufacturer's name PUMPCO		
TOPSOIL		0	3	Type PVC Dia. 5"		
BROWN CLAY		3	10	Slot/gauze 1/4" Length 20'		
SANDROCK		10	15	Set between 60 ft. and 80 ft.		
BLUE CLAY		15	17	Gravel pack? YES Size range of material 1/4" x 1/2"		
SANDROCK		17	68	11. Static water level: _____ mo./day/yr. 42 ft. below land surface Date 8-19-77		
RED CLAY		68	71	12. Pumping level below land surface: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m.		
GRAY CLAY		71	80	Estimated maximum yield 30 g.p.m.		
STOP		80		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 600 Direction EAST Type LOTS Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Geo Cox + Sons Inc 258 Business name _____ License No. _____ Address CLIFTON KANSAS Signed Raymond Cox Date 8-19-77 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 10 S R 3 EW
 Sec 22 NE 1/4 SW 1/4