


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County OTTOWA Fraction SW 1/4 NW 1/4 Sec 1/4 Section number 31 Township number T 10 S R 3 E W Range number 3	
2. Distance and direction from nearest town or city: 1/2 N Street address of well location if in city: MINNEAPOLIS 3. Owner of well: CLIFFORD BOLLIER R.R. or street: R.R. #3 City, state, zip code: Minneapolis, Kans 67467	
4. Locate with "X" in section below: Sketch map: 	
5. Type and color of material	
	From To
TOPSOIL	0 3
BROWN CLAY	3 22
GRAY CLAY	22 24
SANDROCK	24 28
BROWN CLAY	28 42
BROWN CLAY w/ROCK LAYERS	42 48
SANDROCK	48 73
GRAY CLAY	73 81
SANDROCK	81 100
STOP	100
(Use a second sheet if needed)	
18. Elevation: 21285 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. GEORGE & SONS INC 258 Business name License No. Address CLIFTON, KANS Signed David P. [Signature] Date 7/21/76 Authorized representative	

6. Bore hole dia. 8 in. Completion date 7/21/76 Well depth 100 ft.
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 100 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1214
10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Slot gauge 1/16" Length 20' Set between 80 ft. and 100 ft. Gravel pack? Yes Size range of material 15 x 1/4
11. Static water level: 45 ft. below land surface Date 7/21/76 mo./day/yr.
12. Pumping level below land surfaces: <input type="checkbox"/> ft. after N/A hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 35 g.p.m.
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
16. Nearest source of possible contamination: SEPTIC TANK ft. 600 Direction NORTH Type TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other

T 10 S R 3 E W
 Sec 1/4 1/4 1/4
 SW NW SE E W

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5