


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

AIX

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County <u>Sheridan Co.</u> <u>Grove</u>		Fraction <u>SW 1/4 SE 1/4 NE 1/4</u>	Section number <u>20</u>	Township number <u>T 10 S</u>	Range number <u>R 30 W</u>																
X Distance and direction from nearest town or city: <u>Grinnell</u> Street address of well location if in city: <u>1 1/2 S 1/4 E</u>			3. Owner of well: <u>JAMES SCHROEDER</u> R.R. or street: City, state, zip code: <u>GRINNELL KANSAS 67238</u>																		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <u>26</u> in. Completion date <u>8-20-76</u> Well depth <u>130</u> ft.																		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																		
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:80%;">From</th> <th style="width:20%;">To</th> </tr> </thead> <tbody> <tr> <td><u>Clay, Sandstone</u></td> <td><u>70 80</u></td> </tr> <tr> <td><u>M GRAVEL SANDSTONE</u></td> <td><u>80 90</u></td> </tr> <tr> <td><u>SANDY CLAY</u></td> <td><u>90 110</u></td> </tr> <tr> <td><u>CLAY, M GRAVEL</u></td> <td><u>110 114</u></td> </tr> <tr> <td><u>M GRAVEL</u></td> <td><u>114 124</u></td> </tr> <tr> <td><u>Dchrc</u></td> <td><u>124 130</u></td> </tr> <tr> <td colspan="2" style="text-align:center;"><u>BROCK 124'</u></td> </tr> </tbody> </table>			From	To	<u>Clay, Sandstone</u>	<u>70 80</u>	<u>M GRAVEL SANDSTONE</u>	<u>80 90</u>	<u>SANDY CLAY</u>	<u>90 110</u>	<u>CLAY, M GRAVEL</u>	<u>110 114</u>	<u>M GRAVEL</u>	<u>114 124</u>	<u>Dchrc</u>	<u>124 130</u>	<u>BROCK 124'</u>		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From	To																				
<u>Clay, Sandstone</u>	<u>70 80</u>																				
<u>M GRAVEL SANDSTONE</u>	<u>80 90</u>																				
<u>SANDY CLAY</u>	<u>90 110</u>																				
<u>CLAY, M GRAVEL</u>	<u>110 114</u>																				
<u>M GRAVEL</u>	<u>114 124</u>																				
<u>Dchrc</u>	<u>124 130</u>																				
<u>BROCK 124'</u>																					
9. Casing: Material <u>Steel</u> Height: Above <input type="checkbox"/> below <input checked="" type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36</u> lbs./ft. Dia <u>16</u> in. to <u>60</u> ft. depth Wall Thickness: inches or Dia. <u>   </u> in. to <u>   </u> ft. depth Gage No. <u>219</u>			10. Screen: Manufacturer's name <u>W.A. BROWN</u> Type <u>LOUVER</u> Dia. <u>16</u> Slot/gauze <u>1/8" x 7/16"</u> Length <u>70</u> Set between <u>60</u> ft. and <u>130</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4" to 1/2"</u>																		
11. Static water level: <u>80</u> ft. below land surface Date <u>7-29-76</u>			12. Pumping level below land surfaces: <u>118</u> ft. after <u>4</u> hrs. pumping <u>1150</u> g.p.m. <u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m. Estimated maximum yield <u>1150</u> g.p.m.																		
13. Water sample submitted: <u>   </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>   </u>			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade																		
15. Well grouted? <u>YES</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			16. Nearest source of possible contamination: ft. <u>   </u> Direction <u>   </u> Type <u>None</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																		
17. Pump: Not installed Manufacturer's name <u>WESTERN LAND PUMP</u> Model number <u>100</u> HP <u>   </u> Volts <u>   </u> Length of drop pipe <u>130</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			18. Elevation:  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley																		
19. Remarks:  (Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>J &amp; H Drilling Co. Inc. 166</u> Business name <u>   </u> License No. <u>   </u> Address <u>Woodland Kansas</u> Signed <u>Bill Clifford</u> Date <u>8-20-76</u> Authorized representative																		

10 300' 20 SUSSENE  
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5