OAKLEY NE

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

BCC

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Thomas	SW 1/4 SW 1/4 NW 1/4	14	T 10 S	R 32 E/W

2. Distance and direction from nearest town or city: 3½ miles north of Oakley on US 83
Street address of well location if in city:

3. Owner of well: Ross Nelson
R.R. or street: Rt. 2
City, state, zip code: Oakley, Kansas 67748

4. Locate with "X" in section below: Sketch map:

N — NW — NE — X — W — E — SW — SE — S — 1 Mile — 1 Mile

5. Type and color of material	From	To
Top Soil	0	40
Sand	40	46
Clay	46	62
Sand and Rock Strips	62	103
Shale	103	105
BROCK 103'		

(Use a second sheet if needed)

6. Bore hole dia. 8 in. Completion date
Well depth 105 ft. 10-14-76

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material plst Height: Above or below
Threaded __ Welded __ Surface 15" ~~AB~~ in.
RMP X PVC __ Weight __ lbs./ft.
Dia. __ in. to __ ft. depth Wall Thickness: inches or
Dia. 5 in. to 105 ft. depth gage No. ~~.032~~ 320 MNC

10. Screen: Manufacturer's name J and L
Type RMP Dia. 5"
Slot/gauze 1/32" Length ~~2½'~~ 20' MNC
Set between 85 ft. and 105 ft.
__ ft. and __ ft.
Gravel pack? yes Size range of material 1/8"

11. Static water level: mo./day/yr.
125 ft. below land surface Date 10-14-76 MNC

12. Pumping level below land surfaces:
__ ft. after NA hrs. pumping __ g.p.m.
__ ft. after __ hrs. pumping __ g.p.m.
Estimated maximum yield __ g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date

14. Well head completion:
X Pitless adapter 20" Inches above grade

15. Well grouted? yes
With: X Neat cement __ Bentonite __ Concrete
Depth: From 4 ft. to 18 ft.

16. Nearest source of possible contamination:
ft. 270 Direction west Type cesspoll
Well disinfected upon completion? X Yes __ No

17. Pump: X Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.p.m.
Type:
__ Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

T 10 R 32 Sec 14 1/4 SW 1/4 SW 1/4 NW

18. Elevation:
Topography:
__ Hill
__ Slope
X Upland
__ Valley

19. Remarks: 3025 (TOPO)

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name Bartell Drilling License No. 139
Address Winona, Kansas 67764
Signed Jay. Bartell Date 5-1-77
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023